

<b>SUMMER 2021 - RESULTS FOR TESTING OF LEAD IN WATER LEVELS AT 13 APS LOCATIONS</b>
<b>(LATEST BATCH IN ROTATING THREE YEAR CYCLE SHOWN IN THIS 'MAINTENANCE' WEB SECTION)</b>

Collect Date	Location	Param	In Parts/Billion - PPB	
			EPA 200.8	Result
6/10/2021	Ashlawn - Main Kitchen Sink	Lead	EPA 200.8	ND
6/10/2021	Ashlawn - Cafeteria Water Fountain	Lead	EPA 200.8	0.0003
6/10/2021	Arl. Traditional (now Spanish Immersion) - Main Kitchen Sink	Lead	EPA 200.8	ND
6/10/2021	Arl. Traditional (now Spanish Immersion) - Clinic Water fountain	Lead	EPA 200.8	ND
6/10/2021	Campbell - Main Kitchen Sink	Lead	EPA 200.8	ND
6/10/2021	Campbell - Clinic Water Fountain	Lead	EPA 200.8	0.0002
6/10/2021	Carlin Springs - Main Kitchen Sink	Lead	EPA 200.8	ND
6/10/2021	Carlin Springs - Fountain by Room 194	Lead	EPA 200.8	ND
6/10/2021	Glebe - Kitchen Right Faucet	Lead	EPA 200.8	ND
8/5/2021	Glebe - Bottle Filler by Office	Lead	EPA 200.8	ND
6/10/2021	Key (now Innovation) - Right Kitchen faucet	Lead	EPA 200.8	ND
8/5/2021	Key (now Innovation) - Bottle filler by Rm 222	Lead	EPA 200.8	ND
6/10/2021	Long Branch - Bottle filler by Clinic	Lead	EPA 200.8	ND
8/5/2021	Long Branch - Main Kitchen faucet	Lead	EPA 200.8	0.0004
6/10/2021	McKinley (now ATS) - Bottle Filler by Room 338	Lead	EPA 200.8	0.0005
6/10/2021	McKinley (now ATS) - Bottle Filler by Room 210B	Lead	EPA 200.8	ND
8/5/2021	Montessori - Kitchen main faucet	Lead	EPA 200.8	0.0002
6/10/2021	Montessori - Bottle filler outside kitchen	Lead	EPA 200.8	ND
6/10/2021	Nottingham - Bottle Filler by Room 141	Lead	EPA 200.8	ND
6/10/2021	Nottingham - Bottle Filler by Room 110	Lead	EPA 200.8	ND
6/10/2021	Oakridge - Bottle Filler by Room 238	Lead	EPA 200.8	ND
6/10/2021	Oakridge - Bottle Filler in Cafeteria	Lead	EPA 200.8	0.0017
6/10/2021	Swanson - Bottle Filler by Room 136	Lead	EPA 200.8	ND
6/10/2021	Swanson - Bottle Filler by Room 231	Lead	EPA 200.8	ND
6/10/2021	Williamsburg - Bottle Filler by Room 233	Lead	EPA 200.8	0.0004
7/31/2020	Williamsburg - Bottle Filler in Cafeteria	Lead	EPA 200.8	0.0005
<b>NB: Half are at None Detected (ND) the other half are all at miniscule traces. Actionable level is 15.00 PPB</b>				
Any questions on these results can be directed to Jim Meikle, Director of Maintenance APS - 703 228 6617				